

RFI RESPONSE

Marlisa Bustos w/ United Paving, Dated April 15 2022

- Q1. Is contractor responsible to re-seed any landscaping that may driven over with our equipment? If so, what is the seed requirements?
- A1. Yes, plan to smooth out ruts caused by machines, and please see the attachment labeled seed Grass seed spec.
- Q2. The redwood header spec calls for 2x8, however on the map it shows 2x6. Can you please confirm??
- A2. Everything will be 2x8 for all headers throughout the project.
- Q3. Will the school move the storage bins that are currently onsite?
- A3. Yes, the District will move the containers.
- Q4. Who is responsible for the weed kill prior to crack seal?
- A4. The contractor, no products containing glyphosate.
- Q5. Regarding the cracks that are over 1", will you require the contractor to grind 18" and pave?
- A5. No, grind just fill with asphalt and roll flat.
- Q6. The plans call for "asphalt grindings".. Will we dump all grindings onsite? Do we need to roll the grindings?
- A6. Yes, the contractor will dump and spread to roughly 3"-4" depth. No rolling is necessary.
- Q7. Can the school provide the quantities for this project? Without quantities the bid will not be apples to apples, thus making it difficult for a competitive bid.
- A7. Assuming this is in regards to the asphalt grindings, its 14,648 square feet by roughly 3"-4" thick.
- Q8. The seal coat spec calls for a total of 60 gallons to be used.. Is this correct?
- A8. 60 gallons per 1,000 square feet area.
- Q9. Do we need a certified engineer to survey the project? Are the grades going to change?
- A9. No to both.
- Q10. Are we relocating the utilities? Who will be responsible for this?
- A10. No.
- Q.11. Will we have the entire site to ourselves or would we need to consider several phases?

- A11. Carlton oaks will have another contractor onsite. However, they will be out of the contractors way.
- Q12. Does the school have a budget for this project? I see that it's estimated at \$200,000-\$500,000, however looking at the scope and taking into consideration the dump fees for the clay base it may be a \$800,000+ project.
- A12. No.
- Q.13. Can we install the redwood header 1' away from the fence?
- A13. Yes.
- Q14. If the school does not provide quantities, can the contractor go to the sites and field measure for verification?
- A14. Yes.
- Q15. Will we replace the AC berm?
- A15. Only along the south side of the campus indicated by pink arrows.
- Q16. Can you please clarify "extend DG area"?
- A16. Demo existing asphalt to native soil and from tetherball pole to the northeast side of the bench. See video for more information.
- Q17. Does the school want us to price per the soils recommendations? It seems the map reflects the recommendations.
- A17. Yes, price should reflect the recommendations of the soils report.



Home Office
 3441 E. Harbour Drive, Phoenix, AZ 85034
 602.437.9530
 EwingIrrigation.com | EwingLandscapeMaterials.com



QUOTATION

CHARGE ACCT
 * 10982 *

21 Ewing El Cajon
 1923 John Towers Ave
 El Cajon, CA 92020
 PHN 6195623300 FAX 6195620938

QUOTE # 9837009
 PAGE 1 of 1
 ORDERED 4/18/2022
 QUOTE EXPIRES ON 5/18/2022

SOLD TO: SANTEE SCHOOL DISTRICT
 # 123845 9625 CUYAMACA ST
 SANTEE, CA 92071-2674
 PH 6192582289

SHIP TO: SANTEE SCHOOL DISTRICT
 9625 CUYAMACA ST
 SANTEE, CA 92071-2674
 PH 6192582289

DELIVERY INSTRUCTIONS: _____

PO#: Stock BUYER: Chris Erwin PH: _____
 P21 JOB: TURF EIP#: _____ BY: CHRIS G QUOTE#: _____

EWING JOB: _____ JOB REF: TURF

QTY ORDER	ITEM DESCRIPTION	NET	EXTENDED
1	53000107 EMP 50LB ACE/EAGLE RYE BLEND		

Quotes do not include estimated tax. Once invoiced and local tax location is identified, applicable taxes will be calculated and applied.

SUB-TOTAL:
TAX:
AMOUNT DUE:

No recommendation has been made by, or provided to, the seller concerning the use of the pesticide covered by this invoice.
PROPOSITION 65 WARNING: Some of the products on your order may expose you to chemicals that are known to the State of California to cause cancer, birth defects and reproductive harm. Learn more at <https://www.p65warnings.ca.gov/>